



**DESIGN NOTES:**

1. MINIMUM COMPRESSIVE STRENGTH = 4000 PSI @ 28 DAYS
2. INLET BAFFLE AND OUTLET CHAMBER ARE PRECAST AS ONE UNIT WITH TOP SECTION OF THE SEPTIC TANK
3. KEYED JOINTS SEALED WITH BUTYL MASTIC SEALANT
4. EXCAVATION MUST BE AT LEAST 12" WIDER AND LONGER THAN TANK
5. OPTIONAL HEAVY DUTY SEPTIC TANKS FOR DRIVEWAYS, TOPS REINFORCED WITH #4 BAR @ 12" OC EACH WAY

**Aroosta Cast, Inc**

217 Parsons Road  
Presque Isle, ME 04769

Tel/Fax: 207-764-0077 E-Mail: sales@aroostacast.com

DRAWING:

1000 GALLON REGULAR  
SEPTIC TANK

SCALE: N.T.S.

PAGE 1 OF 1